

	METER VAULT V FITTING SC
NO.	DESCRIPTION
1.	ASTM D2737 CTS HDPE POLY PIPE (BLUE) W
2.	FORD SERIES 70 COPPER SETTER (H=21"), W INLET & ASSE APPROVED ANGLE DUAL CHEC OUTLET AND STANDARD BYPASS & CARTRI CHECK VALVE (2" MODEL VBHC74-21W-11-44 (1 $\frac{1}{2}$ " MODEL VBHC76-21B-11-66-NL)
3.	COMPOUND METER (SENSUS OMNI C ² RADIO FURNISHED & INSTALLED BY CITY)
4.	OUTLET LINE AS PER PLAN
5.	BRASS BALL VALVE (MUELLER 300 BALL)
NOTE:	PROVIDE GRIP JOINT FOR COPPER OR PLAS THE METER SETTER SHALL BE NO SMALLER

LATERAL FROM THE MAIN TO THE METER SETTER INSTALLED.

PROVIDE ANY ADDITIONAL PIPE & FITTINGS AS NECESSARY.



- 1. FOR EXISTING LINE, CONTRACTOR SHALL POTHOLE EXISTING PIPE TO VERIFY DEPTH & SHALL ADJUST BOX DEPTH ACCORDINGLY.
- 2. CONTRACTOR SHALL RESTORE ALL SURFACE IMPROVEMENTS TO PRE-CONSTRUCTION CONDITION WHERE REQUIRED.



SECTION

1.5" OR 2" COMPOUND METER - ALTERNATE NO. 2

VALVE AND CHEDULE SIZE JOINT /TRACER WIRE 1.5" OR 2" COMP. WITH BALL VALVE 1.5" OR 2" FLG CK VALVE RIDGE DUAL 4-NL) IO READ 1.5" OR 2" FLG 1.5" OR 2" -1.5" OR 2" -

STIC TUBE AS NEEDED.

R IN SIZE THAN THE

